

# enLink Zone

## LoRaWAN Wireless Environmental Sensor

### Installation Guidance

enLink Zone is a precision instrument which accurately measures key indoor air quality parameters –

- Room temperature
- Relative humidity
- CO<sub>2</sub>\*
- VOC's\*
- Light level (LUX)\*
- Barometric pressure\*
- Occupancy (PIR Sensor)\*

\*Sensor Options

Air quality data is transferred using LoRaWAN long range wireless so the data can be used for control and analysis. Long life battery power allows the freedom to position the unit where it will measure the air experienced by the building occupants.



## Introduction

We spend around 90% of our time indoors – at home, at work, at school, or when we go to shops or restaurants.

Many studies have indicated that poor indoor air quality (IAQ) has a negative effect on health and productivity. Every year, millions of work hours are lost due to minor symptoms, such as headaches, dry throat, nausea, fatigue, and eye irritation, often caused or exasperated by poor indoor air quality.

More severe outcomes can include asthma attacks, infection, poisoning and cancer. Exposure to air pollutants has also been shown to increase the risk of respiratory and cardiovascular diseases, angina, high blood pressure and heart disease.

## CO<sub>2</sub> Monitoring

Measuring CO<sub>2</sub> levels can serve as a good indicator of the indoor air quality. CO<sub>2</sub> concentrations within a building often are used to indicate whether adequate fresh air is being supplied to the space. Indoor CO<sub>2</sub> concentration is directly proportional to the number of people in a building and the ability of the ventilation system to dilute the CO<sub>2</sub> generated by occupants.

Moderate to high levels of carbon dioxide can cause headaches and fatigue, and higher concentrations can produce nausea, dizziness, and vomiting. Elevated levels of CO<sub>2</sub> can also affect performance and productivity. In one study<sup>3</sup> of 24 employees, cognitive scores were 50% lower when the participants were exposed to 1,400ppm of CO<sub>2</sub> compared with 550ppm during a working day.

CO <sub>2</sub> concentration	Remarks / Effect
400ppm	Normal CO <sub>2</sub> concentration in outdoor ambient air
400-1,000ppm	Concentrations typical of occupied indoor spaces with good ventilation
1,000-2,000ppm	Complaints of drowsiness and poor air.
2,000-5,000 ppm	Headaches, sleepiness and stagnant, stale, stuffy air. Lack of concentration, loss of attention, increased heart rate and slight nausea may also be present.
5,000ppm +	Workplace exposure limit (as 8-hour TWA)

## CO<sub>2</sub> and Covid-19

Studies have shown that where there is a high level of exhaled CO<sub>2</sub> in the air, there is also a high level of aerosols. A high concentration of aerosols increases the risk of spreading infection. When an infected person coughs, speaks, or sneezes, a spray consisting of droplets and aerosols is generated, which penetrates air in the room and then spreads<sup>1</sup>.

CO<sub>2</sub> sensors can therefore act as the equivalent of the “Canary in a coal mine” and provide valuable information regarding the air quality and the degree of ventilation. Higher levels of CO<sub>2</sub> levels in an indoor space mean there is a higher chance of transmission if an infected person is present.

Prof John Wenger <sup>2</sup>, director of the Centre for Research into Atmospheric Chemistry in UCC suggests a target of 1,000 ppm if CO<sub>2</sub> is being used as a proxy for Covid in classrooms, and argues that room level transmission is “the key. It’s in the air, and it can fill a room. The amount of the virus in the air can accumulate, and we get an increased exposure. If you’re indoors, in a poorly ventilated room for a long time, then you’re at quite a high risk even if you’re distanced, because the air moves around.”

## Installation Guidance

enLink Zone units are lightweight (approx. 250g) and can be fixed to indoor walls or partitions using a variety of methods including double sided adhesive tape, Velcro, Nano tape, screws and ties.

The quantity of monitoring units to be deployed will depend on which standards are being targeted. For example, WELL™ requires a monitor density of at least one sensor per 325 m<sup>2</sup> [3500 ft<sup>2</sup>] of occupiable space. RESET™ uses the space type and number of occupants in each area to determine the quantity of monitors.

### Sensor Positioning

Care should be taken to position the Zone units so that they are:

- at locations where occupants would typically be seated or standing
- at a height of about 1.1-1.7 m [3.6-5.6 ft] above the finished floor and on the inner walls
- at least 0.5 - 1 m [3.3 ft] away from walls, doors, windows, air supply/exhaust outlets
- at least 1 m [3.3 ft] from the corner of a room
- in places where the temperature is in the range of 10-30 ° C
- at a point where air exhausts from the room (where possible)



### Sensor Orientation

Fix the Zone unit to the wall or partition and ensure that the ventilation grills are at the top and bottom of the enclosure to allow air to pass over the internal sensors.



For Zone units with a PIR motion detector, please refer to the product data sheet which details the PIR sensor detection pattern and range.

For Zone units with a (LUX) light level sensor, position the sensor so it receives light levels representative of the space and so that the sensor is not in any shadows. If required the LUX sensor readings may be offset to compensate for the location and angle of the sensor. Please refer to the Zone Quick Start Guide for further details.

## Sensor Calibration

The Zone unit features high accuracy, long life sensors. The temperature, relative humidity, VOC, CO<sub>2</sub> and light level sensors all have an operational life in excess of 5 years. With the exception of the CO<sub>2</sub> sensor, the sensors are maintenance free and do not require any additional calibration.

The CO<sub>2</sub> sensor uses NDIR optical sensing to provide high accuracy readings ( $\pm 30$  ppm  $\pm 3\%$  of reading). The CO<sub>2</sub> sensor automatically self calibrates using a built-in self-correcting ABC-algorithm. ABC stands for Automatic Baseline Correction.

The ABC-algorithm keeps track of the sensor's lowest reading over a preconfigured time interval and slowly corrects for any long-term drift detected when compared to the expected fresh air value of 400 ppm (or 0.04%vol) CO<sub>2</sub>.

In normal indoor applications, the CO<sub>2</sub> level drops to approximately outside air at some point during a week. By sampling the values for an 8-day period and then comparing the lowest value with the sensors 400 point, the sensor can automatically adjust the zero point if required.

What if a room is occupied 24 hours per day?

If a space is constantly occupied and there are no periods when outside levels drop to background levels, the ABC-algorithm will not work. This is the case for greenhouses or in closed confined spaces where CO<sub>2</sub> levels may always be elevated. For these applications, the ABC-function should be turned off. Without the ABC operating, the sensor should be externally calibrated every year.

What if outside/background levels are higher or lower than 400 ppm?

Sometimes, the lowest level may be higher or lower than the 400 ppm assumed by the self-calibration algorithm. If the background level is known to be another level, for example 450 ppm, then this can be set within the unit.

For many applications like CO<sub>2</sub> based ventilation control, the strategy is based on measuring the difference between inside and outside concentrations. It really does not matter if the lowest level of the concentration is 450 ppm; just knowing the difference between the baseline period and the occupied period is enough to provide adequate ventilation control.

How long will the sensor maintain calibration?

The sensor will maintain calibration as long as it periodically senses a background level of CO<sub>2</sub>. The electronics and components in the sensor are rated for a 15-year life. The sensor should maintain calibration over its working life.

## Battery Installation / Replacement

enLink devices use SAFT LS14500 AA size 3.6 Volt Lithium Thionyl Chloride (Li-SOCl<sub>2</sub>) batteries (non-rechargeable) or direct equivalent.

No other batteries are approved for use in the device.

Lithium Thionyl Chloride batteries have very high energy capacity and must be used and handled with care observing the guidance below.



### WARNING


Risk of death or serious injury from explosion or fire.

- Keep out of sight and reach of children.
- Fire, explosion and burn hazard - do not recharge, short circuit, crush, disassemble, incinerate
- Due to the high terminal voltage (3.6V), they are not suitable as direct replacements for other battery technologies in the same can sizes.
- When not in use the Batteries must be stored in a non-Hazardous Area.
- Do not change batteries in an explosive gas atmosphere.
- When installing batteries, do not snag the battery terminal on the clip or the battery may be damaged. Do not apply excessive force.
- Do not drop. Dropping the battery may cause damage. If a battery is dropped, do not install the dropped battery into the unit. Dispose of dropped battery promptly per local regulations or per the battery manufacturer's recommendations.

### Guidance

- Always install the batteries correctly as per instructions taking great care to observe the battery polarity.
- Ensure that the contact points are clean and conductive.
- All batteries must be the same model from the same manufacturer.
- Do not mix old and new batteries or batteries from different manufacturers.
- Do not heat or attempt to recharge the battery.
- Do not dispose of in a fire.
- Only install approved batteries: SAFT LS14500 Lithium Thionyl Chloride AA Battery 3.6 Volt, or direct equivalent.

### Safe disposal



- Please recycle responsibly, a wide range of schemes are available.
- Do not dispose of in normal waste or in a fire.

## References

<sup>1</sup> Yuguo Li, et al. Evidence for probable aerosol transmission of SARS-CoV-2 in a poorly ventilated restaurant. <https://doi.org/10.1101/2020.04.16.20067728>

<sup>2</sup> <http://publish.ucc.ie/researchprofiles/D004/jwenger>

<sup>3</sup> Allen, Joseph G. et al. Associations of Cognitive Function Scores with Carbon Dioxide, Ventilation, and Volatile Organic Compound Exposures in Office Workers: A Controlled Exposure Study of Green and Conventional Office Environments. <http://nrs.harvard.edu/urn-3:HUL.InstRepos:27662232>

## Technical Support

For technical assistance, please visit the downloads section of our web site at [www.synetica.net](http://www.synetica.net) or email us at [support@synetica.net](mailto:support@synetica.net)